

CERTIFICATE OF APPROVAL No CS 5107

This is to certify that, in accordance with
STS200 General Requirements for Certification of Enhanced Security Products
The undermentioned products of

LATHAM'S SECURITY DOORSETS LTD

35/37 Hainge Road, Tividale, West Midlands, B69 2NY
Tel: 01385 220 050

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:


CERTIFIED PRODUCT
Security Container Doorset

TECHNICAL SCHEDULE
STS201 - Enhanced security
requirements for doorsets to satisfy
the requirements of PAS24

CLASSIFICATION			
Security	Weather	Strength	Material Specific
PAS24 D	BS6375-1 800U	BS6375-2&3 Medium Duty	NPD

NPD = No performance determined

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited



Paul Duggan
Certification Manager

Issued: 4th June 2020
Audit Test Frequency: Annually
Valid to: 3rd June 2025



CERTIFICATE No CS 5107 LATHAM'S SECURITY DOORSETS LTD

Latham's Security Doorsets Ltd – Security Container Doorset

1. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
2. This approval relates to the use of the above in providing an enhanced security performance to PAS24:2016 Annex A & B, a weather performance of 800U to BS6375-1:2015 a mechanical strength performance of Medium Duty to BS6375-2:2009 and an additional performance to BS6375-3:2009 Annex A & C.
3. The doorsets are approved on the basis of:
 - i. Initial type testing against PAS24 & BS6375. Element Wednesbury test reports WIL 419399, WIL 419492 & WIL 422404.
 - ii. Audit testing at the frequency specified in STS 200 & STS 201 where relevant.
 - iii. A design appraisal against STS201 where relevant.
 - iv. Inspection and surveillance of factory production control at Latham's Security Doorsets Ltd, 35/37 Hainge Road, Tividale, West Midlands, B69 2NY and Chongqing Mexin Best Doors & Windows Industry Co. Ltd, No. 56 Baihe Road, Nanping Economy & Technology Developing District, Chongqing, China.
4. This approval is applicable to complete doorsets only.
5. This certification is designed to demonstrate compliance of the doorset specifically with PAS24 and the requirements of Secured by Design. If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
6. This approval is applicable to single-leaf, unglazed, open-out doorsets without sidelights or toplights, without letterplates at leaf dimensions up to those given in Table 1.
7. Approved hardware items are:
 - 4no. Chongqing Number One Technology Co. Ltd Ball Bearing Butt hinge MX-JL4.5 x 4.5# with 4no. Chongqing Mexin Best Doors & Windows Industry Co. Ltd Anti-jimmy bolt MX-FJX01#
 - Zhejiang Hongli Locks Co. Ltd HL8#EX Multipoint sash lock & HL502A side locks & Chongqing Mexin Best Doors & Windows Industry Co. Ltd. shootbolt MX-TJS-002#
 - Zhejiang Hongli Locks Co. Ltd Stainless steel lever handles 918901
 - UAP Ltd 3* Kinetica cylinder 75mm in length KIN35T/35NAS

Signed
E/353 & J/143



Issued: 4th June 2020
Valid to: 3rd June 2025



CERTIFICATE No CS 5107
LATHAM'S SECURITY DOORSETS
LTD

For the full specification of the product please refer to the constructional specification that accompanies this certificate.

Signed
E/353 & J/143

Issued: 4th June 2020
Valid to: 3rd June 2025

CERTIFICATE No CS 5107 LATHAM'S SECURITY DOORSETS LTD

Latham's Security Doorsets Ltd – Security Container Doorset

Configuration	Maximum door leaf width (mm)	Maximum door leaf height (mm)	Door leaf thickness (mm)
Open-out, single leaf (overall leaf size including astragal)	1165	2050	45

Table 1. Permitted Door Leaf Dimensions

Configuration	Maximum frame width (mm)	Maximum frame height (mm)
Single leaf without toplights & sidelights	1210	2065

Table 2. Permitted Frame Dimensions

Note: Under no circumstances must either the maximum height or maximum width be exceeded without separate CERTISECURE approval.

- The doorsets shall be mechanically fixed to wall constructions as described in manufacturers approved installation instructions.
- Labels to the CERTISECURE design referencing CERTISECURE, PAS24 D, Latham's Security Doorsets, and CERTISECURE certificate No. CS 5107 shall be affixed to each doorset in the prescribed position.
- This approval relates to on going production. The doorset and/ its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTISECURE name and mark together with the CERTISECURE Certificate number and application where appropriate.

Signed
E/353 & J/143

Issued: 4th June 2020
Valid to: 3rd June 2025



**CERTIFICATE No CS 5107
LATHAM'S SECURITY DOORSETS
LTD**

Further Information

Further information regarding the details contained in this report may be obtained from Latham's Security Doorsets Ltd 35/37 Hainge Road, Tividale, West Midlands, B69 2NY (Tel: 01385 220 050)

Further information regarding CERTISECURE certification and other approved products can be obtained from Warringtonfire Testing and Certification Limited, Holmesfield Road, Warrington WA1 2DS (Tel: 01925 646 777)

Issued: 4th June 2020
Valid to: 3rd June 2025

Signed
E/353 & J/143

Page 5 of 11